



Rajasthan State Mines & Minerals Limited
(A Government of Rajasthan Enterprise)
SBU & PC-Rockphosphate, P.O. Jhamarkotra-313015,

Ref:- RSMM/Phos/Pur/25-26/ 47

dated 31-07-2025

CORRIGENDUM

Tender reference no. NIT-20/25-26 dated 18-07-2025

Subject:- Supply of power control centre (PCC) panels.

With reference to the above referred tender. Kindly note the following amendments to the tender documents to the extent given below:-

Page No. of NIT	Existing	New
17 (Annexure-C) Point-7	Main Bus bar- Aluminium size 30X6 sqmm/phase with heat shrinkable sleeves.	Main Bus bar- Aluminium size 30X10 sqmm/phase with heat shrinkable sleeves
17 (Annexure-C) Point-8	Outgoing feeder Bus bar- Aluminium size 30X10 sqmm/phase with heat shrinkable sleeves.	Outgoing feeder Bus bar- Aluminium size 30X6 sqmm/phase with heat shrinkable sleeves.
Annexure-A, B & C Point-16	Indications- ON, OFF, TRIP	Indications- ON, OFF, TRIP, R-Y-B (for input power supply)
Annexure-A, B Point-13	Photo Switch: - Auto photo switch 25Amp with sensor	Photo Switch: - Auto photo switch 25Amp with sensor and Auto/Manual/Off switch. Photo switch shall operate 3pole contactor 40Amp (coil-415VAC). Input supply of contactor shall be from output of SFU and its output shall be terminated at Terminal blocks in the panel.

Note:- Other terms & conditions remain same.


General Manager (MM) Jkt